








# INSTALLATION INSTRUCTIONS

## – Duct connection box –

### 1. Accessories

- Check that the following parts are in the box when unpacking.

Supplied parts	Q'ty	Remarks
Duct connection box 	1	
Duct connection box installation bracket 	1	
Duct connection flange (ø100) 	1	Duct flange
Installation screw (4×10) (5/32"×13/32") 	14	
Thermal insulation for installation screws A 	2	Polyethylene foam T2
Thermal insulation for installation screws B 	2	Polyethylene foam T5



### 2. Installation

< Note > Install the duct connection box after installing the indoor unit. Also, because the duct connection box is attached to the air-intake plenum, use sufficient care when handling it. Especially avoid any impacts on the side of the air-intake plenum, as this can result in damage.

- Follow the instructions in the air-intake plenum installation instructions and install the air-intake plenum on the indoor unit.
- (1) Remove the sealing plate from the air-intake plenum.
  - (2) Fit the duct connection flange and installation bracket into the duct connection box. Fasten with the supplied 8 installation screws.
  - (3) Fasten the duct connection box to the air-intake plenum with the 6 installation screws.
  - (4) Apply the supplied thermal insulation A and B to the installation screws.